DECLARATION OF PERFORMANCE

Reference number WFOSB3DoPv11

West Fraser Europe Ltd Morayhill, Dalcross Inverness IV2 7JQ

Unique Identification code of the product type*	Intended Use	Systems of AVCP	Notified Body	Harmonised standard					
OSB/3 >6mm to 32mm*	Internal/external use as structural components in humid conditions	2+	0502	EN13986:2004+A1:2015					
*The unique identification code of the product type is a combination of the technical class and the individual product's nominal thickness									

Declared performance (covering a range of product-types OSB/3 >6mm to 32mm*)

Essential characteristics	Performance														
Thickness range	6 to 10		>10 to <18		18 to 25		>25 to 32		15 T&G 400mm centres		18 T&G 600mm centres		22 T&G 600mm centres		
	0	90	0	90	0	90	0 90		0 - 90		0- 90		0-90		
¹Characteristic Strength (N/mm²) - Bending	18.0	9.0	16.4	8.2	14.8	7.4	NPD	NPD	16.4	8.2	14.8	7.4	14.8	7.4	
- Compression f_c	15.9	12.9	15.4	12.7	14.8	12.4	NPD	NPD	15.4	12.7	14.8	12.4	14.8	12.4	
- Tension f_t	9.9	7.2	9.4	7.0	9.0	6.8	NPD	NPD	9.4	7.0	9.0	6.8	9.0	6.8	
- Panel Shear $f_{\rm v}$	6.8		6.8		6.8		NPD		6.8		6.8		6.8		
- Planar shear f_r	1	.0	1.0		1.0		NPD		1.0		1.0		1.0		
¹ Mean Stiffness values,(MOE) (N/mm²) - Tension E _t	3800	3000	3800	3000	3800	3000	NPD	NPD	3800	3000	3800	3000	3800	3000	
- Compression E _c	3800	3000	3800	3000	3800	3000	NPD	NPD	3800	3000	3800	3000	3800	3000	
- Bending E _m	4930	1980	4930	1980	4930	1980	NPD	NPD	4930	1980	4930	1980	4930	1980	
- Panel Shear G _ν	1080		1080		1080		NPD		1080		1080		1080		
- Compression E _c	5	0	50		50		NPD		50		50		50		
Punching Shear Characteristic strength under point load F _{max,k} (kN) (for floors and roofs)	NI	PD	NPD		NPD		NPD		2.64		4.12		4.96		
Punching Shear Mean stiffness under point load, R (N/mm) (for floors and roofs)	NI	PD	NPD		NPD		NPD		305		489		770		
Racking resistance(for walls) Characteristic Strength F _{Rd,max,k} (N)	NI	PD	NPD		NPD		NPD		NPD		NPD		NPD		
Racking resistance (for walls) Mean Stiffness R _{mean} (N/mm)	NI	PD	NPD		NPD		NPD		NPD		NPD		NPD		
Soft Body Impact resistance Floors/Roofs Walls	NPD		NI	NPD		NPD		NPD		Impact Class 1 Pass Roof		Impact Class 1 Pass Floor		Impact Class 1 Pass Floor	
Embedment strength f _h (N/mm2)	NI	PD	NPD		NPD		NPD		NPD		NPD		NPD		

			Minimum	thickness	Class (excluding floorings)g			Class (Flooring)h				
	Without an air											
	the pan	9		D-s2,d0			D _{fl} ,s1					
	With a closed	0										
	gap ≤ 22mm l panel	9	9		D-s2,d2			-				
	Closed air gap		45									
	panel	15		D-s2,d0			D _{fl} ,s1					
3	With an ope	18			D-s2,d0		D _{fl} ,s1					
² Reaction to fire	behind the			·								
(see notes to table for field of	Any end		3		1 1 - 1	E		E _{fl}				
application details and	a -Mounted without an air gap directly against class A1 or A2-s1, d0 products with minimum density 10kg/m3 or at least class D-s2, d2 products with minimum density 400 kg/m3.											
associated documentation	b -A substrate of cellulose insulation material of at least class E may be included if mounted dir											
references)	against the wood-based panel, but not for floorings.											
-	c -Mounted with an air gap behind. The reverse face of the cavity shall be at least class A2-s1, d0											
		products with minimum density 10 kg/m3.										
	d -Mounted with an air gap behind. The reverse face of the cavity shall be at least class D-s2, d2 p with minimum density 400 kg/m3.											
	r aloce oval	Jacobski (landon)										
	e -Veneered, phenol- and melamine-faced panels are included for class excl. floorings.											
	f -A vapour barrier with a thickness up to 0,4 mm and a mass up to 200 g/m² can be mounted in between the wood-based panel and a substrate if there are no air gaps in between. g -Class Provided for in Table 1 of the Annex to decision 2000/147/EC											
	h -Class Provided for in Table 2 of the Annex to decision 2000/147/EC											
	Wa	ater vapour pe	ermeability (EN:12572:2	001)							
Thickness (mm)	s (mm) 15											
Dry (μ)	207											
Wet (μ)	97											
Release of formaldehyde	E1	E1	E1	E:	1	E1	E1		E1			
Release (content) of pentachlorophenol (PCP)	≤5ppm	≤5ppm	≤5ppm	≤5p	pm :	≤5ppm	≤5ppm	ı	≤5ppm			
Airborne sound insulation (surface mass) R (dB)	NPD	NPD	NPD	NP	D	NPD	NPD		NPD			
³ Sound absorption Frequency	0.1	0.1	0.1	0.	1	0.1	0.1		0.1			
range 250Hz to 500Hz (α) 3Sound absorption Frequency	+											
range 1000Hz to 2000Hz (α)	0.25	0.25	0.25	0.2	25	0.25	0.25		0.25			
Thermal conductivity λ	0.13	0.13	0.13	0.1	12	0.13	0.13		0.13			
(W/m.K)												
Air Permeability V ₀ (m3/h)	NPD	NPD	NPD	NP	D	NPD	NPD	NPD				
			Durability									
Internal bond (N/mm²)	0.34	0.32	0.30	0.2	29	0.32	0.32		0.30			
Swelling in thickness (%)	15	15	15	15	5	15	15		15			
Bending strength after cyclic test – major axis (N/mm²)	9	8	7	6		8	8		7			
4Mechanical												
(creep k _{def}) Service class 1	1.5	1.5	1.5	1.	5	1.5	1.5		1.5			
⁴ Mechanical	2.25	2.25	2.25	2.7)E	2.25	2.25		2.25			
(creep k _{def}) Service class 2	2.25	2.25 2.25		2.25 2.3		2.25	5 2.25		2.25			
Mechanical (duration of load	Action Mode											
k _{mod})	Permanent	Long	Term	Mediu	m Term	Short Term		Instantaneous				
⁴ Service class 1	0.4	0	.5	0	0.7		0.9		1.1			
⁴ Service class 2	0.3	0	.4	0.	55	0.7		0.9				
Biological		Use classes 1 & 2						1				

NOTES TO TABLE

1 Taken from EN 12369-1:2001

2 reaction to fire classes from Table 1 of Commission Decision 2003/43/EC of January 2003 (OJEU L13 of 18.1.2003) corrected by Corrigendum (OJEU L33 of 8.2.2003) and amended by Commission decision 2007/348/EC of May 2007 (OJEU L131 of 23-05-2007); also reproduced in Table three of EN 13986:2004+A1:2015 for wood-based panels installed according to CEN/TR 12872

3 Taken from Table 10 of EN 13986:2004+A1:2015

4 Taken from Eurocode 5 EN 1995-1-1 2004+A2:2014

The performance of the product identified is in conformity with the declared performance.

This declaration of performance is issued in accordance with regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Steve McTaggart (HSEQ Manager)

S. 195-80-

At: Inverness, Scotland On: 03 July 2023